



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT

Name and Address of Organization/ Customer	Director Royal Public School Iqbalpur Road Jhabrera, Roorkee.		
Test Report ID	280/UJS/DLWQTML/2025-26	Reporting Date	29/07/2025
		Sample Location	Director Royal Public School. Roorkee.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-280		
Date of Start of Analysis:	26/07/2025		
Date of End of Analysis:	28/07/2025		
Date and Time of Sample Received:	26/07/2025 & 11:30 Am		

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	Nitrate, mg/L, max	APHA 23 RD Ed. 4500- NO ₃ -B	3.16	45	No Relaxation
2.	Sulfate, mg/L, max	APHA 23 RD Ed. 4500-SO ₄ 2 -E	5.34	200	400
3.	Iron (as Fe), mg/L, max	APHA 23 RD Ed. 3500- Fe - B	Less than 0.5	1.0	No Relaxation
4.	Flouride, mg/L, max	APHA 23 RD Ed. 4500- F - D	Less than 0.2	1.0	1.5
5.	Residual Free Chlorine, mg/L, Min	APHA 23rd Ed.-4500- Cl-G	NA	0.2	1.0
Bacteriological Parameters					
6.	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
7.	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Gagan
District Water Quality Testing Monitoring
Laboratory,
Uttarakhand Jal Sansthan, Haridwar

Anjali
(Er. Anjali Palariya)

Review and Authorized By
Authorized Signatory,
District Water Quality Testing Monitoring
Laboratory,
Uttarakhand Jal Sansthan, Haridwar



District Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar

Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TC-12836

TEST REPORT


Name and Address of Organization/ Customer	Director Royal Public School Iqbalpur Road Jhabrera, Roorkee.		
Test Report ID	280/UJS/DLWQTML/2025-26	Reporting Date	29/07/2025
ULR No.	TC128362400000121F	Sample Location	Director Royal Public School, Roorkee.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-280		
Date of Start of Analysis:	26/07/2025		
Date of End of Analysis:	28/07/2025		
Date and Time of Sample Received:	26/07/2025 & 11:30 Am		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022.	7.29	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	316	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.25	1	5
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	IS 3025 (Part 23), 2023	186	200	600
5.	Total Hardness (as CaCO ₃), mg/L, Max	IS 3025 (Part 21), 2009	238	200	600
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	60.8	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	14	250	1000
8.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	20.89	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	Less than 1	5	15
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****


District Water Quality Testing Monitoring
Laboratory,
Uttarakhand Jal Sansthan, Haridwar


(Er. Anjali Palariya)
Review and Authorized By
Authorized Signatory,
District Water Quality Testing Monitoring
Laboratory,
Uttarakhand Jal Sansthan, Haridwar

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 49 / जल प्रयोगशाला

Dated: 30/07/25

It is certified that an inspection team headed by **Girish Jaguri (chemist)** (Officers with designation) from Uttarakhand Jal Sansthan Mayapur Haridwar inspected the **Director Royal Public School Iqbalpur Road Jhabrera, Roorkee**, (Name & Address of the school) on **30/07/2025** (date of inspection) and on the basis of Water Test Report (Attached) bearing no 280/UJS/DLWQTML/2025-26 dated 29/07/2025 of DLWQTML certified that the **Director Royal Public School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution, School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T.Govt.

This certificate is valid till 28/07/2026

Signature with Seal: _____

Name: Girish Jaguri

Designation: Chemist UJS

**District Water Quality Testing Monitoring Laboratory ,
Uttarakhand Jal Sansthan, Haridwar**

Name & Address of the Office/Department: Jal kal office mayapur haridwar.

To

Director Royal Public School,

Iqbalpur Road Jhabrera Roorkee.

(Name& Address of the Institution)

Note: The certificate is to be issued by authorized officer /PHED Lab / local bodies